


## Rutland West Solar Farm - Plan Review

---

From Joe Buschbacher <JBuschbacher@huntleyfpd.org>  
Date Wed 12/11/2024 8:14 AM  
To Robert McNeill <robertmcneill@suryapowered.com>

 1 attachment (84 KB)

Rutland West Solar Farm - Review #1.docx;

Robert,

The Huntley Fire Prevention Bureau has reviewed the drawings for the above project and **approve** with attached comments. If you have any questions, please feel free to contact me directly.

Regards,

Joe



**Joseph S. Buschbacher, CFPE**  
Fire Marshal  
Huntley Fire Protection District  
11118 Main St., Huntley, IL 60142  
jbuschbacher@huntleyfpd.org  
Office - 847-669-5066  
Cell - 847-980-1847



# HUNTLEY FIRE PROTECTION DISTRICT

11118 East Main Street Huntley, Illinois 60142

P 847-669-5066 F 847-669-0139

## Solar Farm Plan Review #1

The Huntley Fire Protection Fire Prevention Bureau has reviewed the plans submitted for:

Site Name: **Rutland West Solar Farm**

Site Address: **Reinking Rd & IL 21, Hampshire**

Date of Review: **12/11/2024**

Based on the information provided, The Huntley Fire Prevention Bureau **approves** the submitted plans with comments below.

PLAN REVIEW INFORMATION	
Specific Review Type:	Solar Farm
Review Cycle:	#1
Date submittal received in HFPD office:	12/06/2024
Number of drawings received:	1 Digital

### GENERAL COMMENTS:

1. The Huntley Fire Protection District will need to have access to any shut-off that controls the array field located within our district. (Far North Array Field)
2. Fire apparatus roads shall be capable of supporting Tower 981 (75,000 lbs.)
3. Knox Boxes will be required at gate for emergency access. Can be purchased directly through Knox Box [www.knoxbox.com](http://www.knoxbox.com) Contact the Fire Prevention Bureau with any questions. 847-669-5066.

Joseph Buschbacher  
Fire Marshal  
Huntley Fire Protection District  
847-669-5066  
[jbuschbacher@huntleyfpd.org](mailto:jbuschbacher@huntleyfpd.org)